

# VOC Content Test Certificate

Friday April 13<sup>th</sup>, 2012

Manufacturer: Ardex Australia (20 Powers Rd, Seven Hills, NSW 2147)

Sample Description: Ardex Multiprime

Date Tested: March 2012 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

<b>Specification</b>  <b>Green Building Council of Australia</b> <b>Green Star Office Design V3 IEQ-13</b>	<b>Ardex Multiprime*</b>
Interior sealer  65 grams per Litre as VOC content per material	<b>14 grams per Litre as VOC content per material</b>

\*Calculation based on manufacturers supplied water content



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Anne Saletti  
BNanotech/BSc(Hons)  
Consultant

CV120311a