

# VOC Content Test Certificate

Tuesday, 12<sup>th</sup> April 2016

Manufacturer: Ardex Australia Pty Ltd (20 Powers Road, Seven Hills, NSW 2147).

Sample Description: Ardex WR Prime

Date Tested: April 2016 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

<p><b>Specification</b></p> <p><b>Green Building Council of Australia</b> <b>Green Star Design &amp; As Built V1.1 13.1.1</b> <b>Green Star Interiors V1.1 12.1.1B</b></p>	<p><b>Ardex WR Prime</b></p>
<p>Primers, Sealers, and Prep Coats: 65 grams per Litre as VOC content per material</p>	<p><b>28 grams per Litre as VOC content per material</b></p>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Tuan Duong  
BE (Chem. Eng.)  
Consultant



Nick Joy  
BSc (Hons)  
Consultant

CV160337