

VOC Content Test Certificate

Thursday April 7th, 2011

Manufacturer: Durotech Industries (15 Essex St, Minto, NSW, 2566)

Sample Description: Duromastic P15

Date Tested: March 2011 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168

Test Data:

Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13	Duromastic P15
Architectural sealant 250 grams per Litre as VOC content material	9 gram per Litre as VOC content per material



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F1103-42