

VOC Content Test Certificate

Monday February 23rd, 2009

Manufacturer: Laticrete Pty Ltd (464 Geelong Road, West Footscray Victoria 3012)

Sample Description: Laticrete[®] 4237 / 211 high strength latex thin-set bed up for installing all types of ceramic tile, natural stone and agglomerates

Date Tested: February 2009

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<p align="center">Specification</p> <p>Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11</p>	<p align="center">Laticrete 4237 / 211</p>
<p>Ceramic Tile Adhesive 65 grams per Litre</p>	<p>37 grams per Litre as VOC content per coating</p>
<p align="center">Specification</p> <p>Green Building Council of Australia Green Star Office Design V3 IEQ-13</p>	<p align="center">Laticrete 4237 / 211</p>
<p>Ceramic Tile Adhesive 65 grams per Litre</p>	<p>37 grams per Litre as VOC content per coating</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F0902-11