

# VOC Content Test Certificate

Monday February 23<sup>rd</sup>, 2009

Manufacturer: Laticrete Pty Ltd (464 Geelong Road, West Footscray Victoria 3012)

Sample Description: Laticrete<sup>®</sup> Lataflex Gold flexible multipurpose adhesive for tile and natural stone

Date Tested: February 2009

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<p align="center"><b>Specification</b></p> <p><b>Green Building Council of Australia</b> <b>Green Star Office Design V2 IEQ-13</b> <b>Green Star Office Interiors V1.1 IEQ-11</b></p>	<p><b>Lataflex Gold</b></p>
Ceramic Tile Adhesive 65 grams per Litre	<b>17 grams per Litre as VOC content per coating</b>
<p align="center"><b>Specification</b></p> <p><b>Green Building Council of Australia</b> <b>Green Star Office Design V3 IEQ-13</b></p>	<p><b>Lataflex Gold</b></p>
Ceramic Tile Adhesive 65 grams per Litre	<b>17 grams per Litre as VOC content per coating</b>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

F0902-11