

VOC Content Test Certificate

Monday February 23rd, 2009

Manufacturer: Laticrete Pty Ltd (464 Geelong Road, West Footscray Victoria 3012)

Sample Description: Laticrete[®] Ultra X8 Fibre & Polymer Fortified Flexible Multipurpose Adhesive for porcelain, vitrified, ceramic and stone tile

Date Tested: February 2009

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<p align="center">Specification</p> <p>Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11</p>	<p>Ultra X8</p>
Ceramic Tile Adhesive 65 grams per Litre	13 grams per Litre as VOC content per coating
<p align="center">Specification</p> <p>Green Building Council of Australia Green Star Office Design V3 IEQ-13</p>	<p>Ultra X8</p>
Ceramic Tile Adhesive 65 grams per Litre	13 grams per Litre as VOC content per coating



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F0902-11