Warringtonfire Australia ABN: 81 050 241 524 P: 03 9767 1000 Unit 2, 409-411 Hammond Rd Dandenong VIC 3175 Australia

Certificate of test

RTF200455 SFC1.0

This is to certify that the product described below was tested by this laboratory at the request of the test sponsor in accordance with AS 1530.1:1994 (R2016).

Test sponsor Rockcote Enterprises Pty Ltd Address 18 Machinery Road

Yandina QLD 4561 Australia

Product name Quick Render Off-White

Test specimen The material is comprised of Off-White Portland Cement, silica sand, mineral and

organic additives, as nominated by the test sponsor. The material was grey in

colour and had an as received measured density of 1,720 kg/m³.

Date of test 25 and 26 November 2020 **Test report** RTF200455 R1.0

Test standard AS 1530.1:1994 (R2016)

Test results

The material is not deemed combustible according to the test criteria for combustibility specified in clause 3.4 of AS 1530.1:1994 (R2016).

Conditions/validity

- This certificate is provided for general information only and does not comply with the regulatory requirements for evidence of compliance.
- Please refer to the relevant test report to determine the applicability of the test result to a proposed installation and for a full description of the tested construction.
- The results of these fire tests may be used to assess fire hazard, but it should be recognised that a single test method will not provide a full assessment of fire hazard under all conditions.
- All work and services carried out by Warringtonfire Australia are subject to, and conducted in accordance with our standard terms and conditions. These are available on request or at https://www.element.com/terms/terms-and-conditions.

Signed on behalf of Warringtonfire Australia

Atousa Aris

Fire testing engineer

Issue date 30 November 2020