

# VOC Content Test Certificate

Thursday October 16<sup>th</sup>, 2008

Manufacturer: Ardex Australia Pty Ltd (Unit 7, 20 Powers Road Seven Hills NSW 2147)

Sample Description: Ardex FS DD tile grout

Date Tested: October 2008

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

|   |   |
|---|---|
| <b>Specification</b><br><br><b>Green Building Council of Australia</b><br><b>Green Star Office Design V2 IEQ-13</b><br><b>Green Star Office Interiors V1.1 IEQ-11</b> | <b>Ardex FS DD</b>                                  |
| Ceramic Tile Adhesive 65 grams per Litre as VOC content material  | <b>4 grams per Litre as VOC content per coating</b> |
| <b>Specification</b><br><br><b>Green Building Council of Australia</b><br><b>Green Star Office Design V3 IEQ-13</b>   | <b>Ardex FS DD</b>                                  |
| Ceramic Tile Adhesive 65 grams per Litre as VOC content material  | <b>4 grams per Litre as VOC content per coating</b> |



Dr. Vyt Garnys  
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
 ACA, AIRAH, FMA  
 Managing Director and Principal Consultant

F0810-04